

City of San Juan Bautista

Notice to Planholders

**ADDENDUM NO.3**

August 14, 2008


OWNER: City of San Juan Bautista  
TO: All Planholders of Record  
FROM: Anne Hall, Design Engineer  
BID DATE: 19 August, 2008, 2:00 P.M.

Notice is hereby given to prospective bidders that the Plans and Specifications for the San Juan Bautista Infrastructure Program Project, dated May 2008, have been modified as herein set forth. This Addendum No. 1 shall form a part of the Contract Documents and takes precedence over the original contract documents.

Bidder shall acknowledge receipt of the addendum in the space below and include this page with the Proposal. Failure to do so may subject the bidder to disqualification.

The date of the bid opening **is not** changed by this addendum. The location of the bid opening **is not** changed by this addendum.

By:



Anne E. Hall

Design Engineer

San Benito Engineering & Surveying



I acknowledge receipt of Addendum No. 3 consisting of 2 pages

Signed \_\_\_\_\_

Company \_\_\_\_\_

<u>Addendum Item</u>	<u>Page or Drawing</u>	<u>Location and Description of Changes</u>
1	7 of 38	ADD: 2" purple line service to Abbe Park. From proposed 6" purple line in 4 <sup>th</sup> St, between Muckelemi and Polk streets, add a 2" line w/ 2" isolation valve, capped at 10' outside right of way. Exact location to be field determined. Pay for this work to be included in bid item 33.

Several questions received from bidders were addressed in Addendum 1. Some bidders have asked for further clarification. *Italics are the answer given in Addendum 1.* [Clarification is in brackets].

Q4. Is there any as built information on the existing roadway sections, specifically location and quantity of existing concrete under the asphalt? This will play a major factor in the pricing for the trenching and the roadway demolition. If not how should the unknown quantities of concrete demo be handled?

A4. *No as built information is available. For bid purposes, assume 6" concrete below the asphalt on 3<sup>rd</sup>, Tahualami & 4<sup>th</sup> St (Bid Item 5.) Any additional quantities of concrete to be removed to be paid for under new Bid Item 62. See page 9.* [Assumption of 6" concrete applies to all streets (Bid Item 6 & 7). While there is no specific reason to believe that there is concrete under the asphalt on these streets, the proximity of a concrete plant to the downtown and the lack of as-built information means that concrete is a possibility. The intent of bid item 62 is only for additional concrete to be removed when greater than 6" in depth in any trenching done as part of this project.]

Q21. Will the award be made on the basis of the BASE BID?

A21. *Award will be made at the discretion of the City of San Juan Bautista on the basis of the most favorable combination of the base bid and one or more, if any, of the deducts.* [The lowest bid shall be determined in a manner that prevents any information that would identify any bidders or proposed subcontractors or suppliers from being revealed to the public entity before the ranking of all bidders from lowest to highest has been determined.]