

City of San Juan Bautista

Notice to Planholders

ADDENDUM NO. 4

August 11, 2008

OWNER: City of San Juan Bautista

PROJECT: San Juan Bautista Treated Water Reservoir

TO: All Planholders of Record


FROM: Chris Morrison, Project Manager

BID DATE: 14, August 2008, 2:30 PM

Notice is hereby given to prospective bidders that the Plans and Specifications for the San Juan Bautista Treated Water Reservoir Project, dated May 2008, have been modified as hereinafter set forth. This Addendum No. 4 shall form a part of the Contract Documents and takes precedence over the original Contract documents.

Bidder shall acknowledge receipt of this addendum in the space below and include this page with the Proposal. Failure to do so may subject bidder to disqualification.

The date of bid opening is not changed by this addendum. The location is not changed by this addendum.

By: 

Christopher Morrison
Project Manager
MWH Americas Inc.



I acknowledge receipt of Addendum No. 4 consisting of 1 pages (excluding attachments).

Signed _____

Contractor _____

THIS PAGE INTENTIONALLY BLANK

Addendum Item	Page or Drawing	Location and Description of Changes
32	03314B	Section 03314B-2.6-A – REPLACE “ASTM A821” with “ASTM A421”.
33	03314B	Section 03314B-3.5-A – DELETE “Stressing may be accomplished by drawing the wire through a die or by another process that results in uninterrupted elongation, thus assuring uniform stress throughout its length and over the periphery of the tank”.

- END OF ADDENDUM -